

DCSD LAN Fiber-CAT6e Cabling Installation Project

Douglas County School District

1638 Mono Avenue

Minden NV 89423

Addendum One

January 24, 2018

1. In consideration of the question around CAT 6 cabling requirement for the DHS network project, we are asking that the CAT 6 cable be at a minimum matching or equivalent to Belden Part Number 2412 - CAT6+ Horizontal, 4pr, UTP, PVC Jkt, CMR.
2. The requirement for data cabling to meet a 25 year warranty is now reduced to a 5 year warranty. This warranty requirement reduction is for the data cable only. All fiber cabling, data terminations and other hardware must meet warranties as stated in the RFP.